

### **Bureau of Fire Prevention**

Entrance Door Fire Emergency Markings (Effective 3/30/2018)

**NYC** Bill de Blasio Mayor

**FDNY** Daniel A. Nigro Commissioner

# **R-1 and R-2 Occupancies**



Directional signs serve to assist emergency response personnel in locating dwelling units.
Required for:

- unsprinklered buildings with more than 8 dwellings on a floor.
- Multi floor dwelling units
- Stairwell doors\*

\*Excludes buildings fully protected by sprinkler system



## Markings and Symbols



The numbers and letters identify the dwelling unit.

The star identifies the *main entrance* to the dwelling.


The triangle identifies each secondary entrance.



The arrows identify living spaces above or below entrance.



**"Sandwich design."** The direction of the arrow shows location of living space, the horizontal line identifies no living space on that floor.






## For Example



Dwelling unit designated as 10A and has a single entrance



Top of marking 12" from the floor







### Dwelling unit:

- 12A
- A single entrance
- A multi-floor dwelling
- Living space on entry floor and floor above



	$\mathbf{\star}$	
	1	1
	4	5
-	Α	Α
	15A	
		14



A



- 14A is main
  - entrance
- 15A is secondary entrance
- Living space on entry floor (14A) and floor above (15A)



#### "Sandwich Design"





Each has single entrance on same floor.



living space
on entry
floor, living
space is

floor above.

• 17B: living space on entry floor

1

7

В

1

7

С

17C: No living
space on entry
floor, living space
is floor below



## **More Information**



Fire Code: FC 505.3-505.4

https://www1.nyc.gov/site/fdny/about/resources/code-andrules/nyc-fire-code.page

FDNY Rules: 3 RCNY 505-01 and 505-02 <u>https://www1.nyc.gov/assets/fdny/downloads/pdf/about/fdny-rules.pdf</u>

NYC Fire Code Guide: Chapter 5 (FAQ #40-50) <u>http://www1.nyc.gov/assets/fdny/downloads/pdf/business/nyc-fire-code-guide.pdf</u>