

Fire Safety and Evacuation Plan (Appendix E-5)

Public Assembly

Occupancies voice communication

ARENA BOWL **SEATING PLAN**

Instructions

A seating plan card must be configured in the format set forth as Appendix E-5, must be maintained at the fire command center, and made available to Fire Department representatives or emergency response personnel, upon request. The Seating Plan Card (SPC) must be 11" x 17" in size, and must be prepared for each seat arrangement approved by the FD LPPA Unit. All the Seating Plan Cards (SPC), must be laminated.

Each side MUST be labeled identifying or designating the seating configuration (example, Seating Plan A, Concert arrangement). The SPC requires detailed seating information, including level identification, exit designation, section designations including seating capacity. The SPC must designate standing room sections & handicap sections. Additionally, information regarding elevators, escalators stairwells & two-way FS phone locations.

A different card must be available for each configuration with the designation clearly marked: (example, Seating Plan A, Concert arrangement) Both sides of each card may be used.