

Table 2. Summary of Bacteriological Data in water samples collected from the Jacob Riis Houses, September 24, 2022.

Apartment #	Client Sample ID	Lab Number	Sample Date	Total Coliform	E. Coli	HPC <sup>1</sup> (MPN/mL) <sup>2</sup>
				Guidance Values <sup>3</sup>	Negative	Absent
				HPC <sup>1</sup> (MPN/mL) <sup>2</sup> < 500 cfu/mL <sup>4</sup>		
Riis Houses Bldg 5						
█	█ Kitchen Sink	2092401-01	9/24/2022	Negative	Absent	26.0
█	█ Kitchen Sink	2092401-02	9/24/2022	Negative	Absent	17.0
█	█ Kitchen Sink	2092401-03	9/24/2022	Negative	Absent	30.0
█	█ Kitchen Sink	2092401-04	9/24/2022	Negative	Absent	6.00
Riis Houses Bldg 4						
█	█ Kitchen Sink	2092402-01	9/24/2022	Negative	Absent	28.0
Riis Houses Bldg 2						
█	█ Kitchen	2092403-01	9/24/2022	Negative	Absent	<2.00
█	█ Kitchen	2092403-02	9/24/2022	Negative	Absent	112
█	█ Kitchen	2092403-03	9/24/2022	Negative	Absent	6.00
█	█ Kitchen	2092403-04	9/24/2022	Negative	Absent	21.0
Riis Houses Bldg 11						
Point of Entry	Point of Entry	2092404-01	9/24/2022	Negative	Absent	23.0
█	█ Kitchen	2092404-02	9/24/2022	Negative	Absent	2.00
█	█ Kitchen	2092404-03	9/24/2022	Negative	Absent	6.00
█	█ Kitchen	2092404-04	9/24/2022	Negative	Absent	4.00
█	█ Kitchen	2092404-05	9/24/2022	Negative	Absent	2.00
Roof Tank	Roof Tank	2092404-06	9/24/2022	Negative	Absent	4.00
Riis Houses Bldg 14						
█	█ Kitchen	2092405-01	9/24/2022	Negative	Absent	2.00
█	█ Kitchen	2092405-02	9/24/2022	Negative	Absent	2.00
█	█ Kitchen	2092405-03	9/24/2022	Negative	Absent	2.00
█	█ Kitchen	2092405-04	9/24/2022	Negative	Absent	<2.00
Riis Houses Bldg 10						
█	█ Kitchen	2092406-01	9/24/2022	Negative	Absent	23.0
█	█ Kitchen	2092406-02	9/24/2022	Negative	Absent	21.0
█	█ Kitchen	2092406-03	9/24/2022	Negative	Absent	6.00
█	█ Kitchen	2092406-04	9/24/2022	Negative	Absent	4.00
Riis Houses Bldg 13						
█	█	2092407-01	9/24/2022	Negative	Absent	<2.00
█	█	2092407-02	9/24/2022	Negative	Absent	6.00
█	█	2092407-03	9/24/2022	Negative	Absent	<2.00
█	█	2092407-04	9/24/2022	Negative	Absent	2.00
Riis Houses Bldg 15						
█	█	2092408-01	9/24/2022	Negative	Absent	19.0
█	█	2092408-02	9/24/2022	Negative	Absent	<2.00
█	█	2092408-03	9/24/2022	Negative	Absent	4.00
█	█	2092408-04	9/24/2022	Negative	Absent	2.00
Riis Houses Bldg 6						
█	█ Kitchen Sink	2092409-01	9/24/2022	Negative	Absent	10.0
█	█ Kitchen Sink	2092409-02	9/24/2022	Negative	Absent	2.00
█	█ Kitchen Sink	2092409-03	9/24/2022	Negative	Absent	12.0
█	█ Kitchen Sink	2092409-04	9/24/2022	Negative	Absent	<2.00
Riis Houses Bldg 8						
Point of Entry	Point of Entry	2092410-01	9/24/2022	Negative	Absent	2.00
█	█ Kitchen Sink	2092410-02	9/24/2022	Negative	Absent	26.0
█	█ Kitchen Sink	2092410-03	9/24/2022	Negative	Absent	33.0
█	█ Kitchen Sink	2092410-04	9/24/2022	Negative	Absent	80.0
█	█ Kitchen Sink	2092410-05	9/24/2022	Negative	Absent	6.00
Roof Tank	Roof Tank	2092410-06	9/24/2022	Negative	Absent	4.00
Riis Houses Bldg 5						
█	█ Kitchen Sink	2092411-01	9/24/2022	Negative	Absent	6.00
Riis Houses Bldg 3						
█	█ Kitchen Sink	2092412-01	9/24/2022	Negative	Absent	15.0
█	█ Kitchen Sink	2092412-02	9/24/2022	Negative	Absent	45.0
█	█ Kitchen Sink	2092412-03	9/24/2022	Negative	Absent	33.0
█	█ Kitchen Sink	2092412-04	9/24/2022	Negative	Absent	38.0
Riis Houses Bldg 19						
█	Kitchen (█)	2092413-01	9/24/2022	Negative	Absent	12.0
█	Kitchen (█)	2092413-02	9/24/2022	Negative	Absent	30.0
█	Kitchen (█)	2092413-03	9/24/2022	Negative	Absent	19.0
█	Kitchen (█)	2092413-04	9/24/2022	Negative	Absent	8.00
Riis Houses Bldg 18						
█	Kitchen (█)	2092414-01	9/24/2022	Negative	Absent	10.0
█	Kitchen █	2092414-02	9/24/2022	Negative	Absent	6.00
█	Kitchen █	2092414-03	9/24/2022	Negative	Absent	17.0
█	Kitchen █	2092414-04	9/24/2022	Negative	Absent	<2.00

Notes

1. HPC - Heterotrophic Plate Count
2. MPN/mL – Most Probable Number per Milliliter (MPN/mL), which correlates with Colony Forming Units per Milliliter (cfu/mL)
3. Guidance Values - US EPA National Drinking Water Regulation
4. Colony Forming Units per milliliter (cfu/mL)
5. Bold data indicates an exceedance of Guidance Values