

ADVISORY BOARD CALENDAR

June 14, 2006

Calendar #	Submission #	Type of Request	Status	Fee
46793CO	06A0530CO	Requested approval for the electric service equipment proposed to be installed	Hold	\$0.00
Carry over from November 16, 2005 meeting. New drawings must be submitted.				
46915CO3	06A0031CO3	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over from March 15, 2006 meeting.				
47035CO	06A0121CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over from March 15, 2006 meeting.				
47091CO	06A0214CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over from April 12, 2006 meeting. Need GF scheme. Provide sequence of operator of the ground fault. Job finalized 7/14/06. 3/9/2022 Amended Plan # 1 of 2 Rev-4 and # 2 of 2 Rev-3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 11/14/2022 Amended plans # 1 & 2 Rev 5. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
47093CO	06A0169CO	Requested approval for the electric service equipment proposed to be installed	Hold	\$0.00
Carry over from April 12, 2006 meeting. Drawing need more details wire and fuse sizes.				

ADVISORY BOARD CALENDAR

June 14, 2006

Calendar #	Submission #	Type of Request	Status	Fee
47121CO2	-----	Requesting permission due to ground water conditions to run service entrance conductors in overhead troughs within a two hour fire rated room instead of concrete encased conduits (Cal. #42541).	Approved	\$0.00
Carry over from May 24, 2006 meeting.				
47137CO	06A0254CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over from May 24, 2006 meeting.				
47187CO	06A0234CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over from May 24, 2006 meeting. 11/10/2020 Contractor Name Change				
47190CO	06A0282CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over May 24, 2006 meeting.				
47191CO	06A0283CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over from May 24, 2006 meeting..				

ADVISORY BOARD CALENDAR

June 14, 2006

Calendar #	Submission #	Type of Request	Status	Fee
47194CO	06A0286CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over from May 24, 2006 meeting.				
47205CO	Requesting permission to install Schedule 80 non metallic conduit for three outdoor free standing services, distribution panels, site lighting and bollard lighting in a corrosive area, Far Rockaway, Queens.	Approved	\$0.00
Carry over from May 24, 2006 meeting.				
47215CO	06A0229CO	Requested approval for use in new York City of your TA 100 Microturbines, Model/Series Number: TA100-CHP,-Monogen.	Hold	\$0.00
Carry over from May 24, 2006 meeting. Listing of overall product must be listed by a Nationally Recognized Testing Laboratory(NRTL) and evaluated to be compliant with documents or standards.				
47217	06A0294	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
47218	06A0293	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Block access behind Switchboard "D". 2) Provide egress door near Switchboard "D". 3) Provide fuse sizes for FCO's. 4) Show bonding in FCO's. Job finalized 7/18/06.				

ADVISORY BOARD CALENDAR

June 14, 2006

Calendar #	Submission #	Type of Request	Status	Fee
47219	06A00290	Requested approval for the electric service equipment proposed to be installed	Ok, but	\$650.00
1) Line side bus of 3000A service switch undersized. 2) Verify F.A. feeders 30 4W or 10 3W? 2p ATS? 3) Confirm sp. Service fire pump loc. Above street level.				
47220	06A0292	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Tap conductors undersized with derating for 2 sets in 1 conduit. Job finalizaed 07/18/06.				
47221	06A0295	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
47222	06A0297	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
47223	06A0299	Requested approval for the electric service equipment proposed to be installed	Ok, but	\$650.00
Tenants storage gates inside of service room?				

ADVISORY BOARD CALENDAR

June 14, 2006

Calendar #	Submission #	Type of Request	Status	Fee
47224	06A0301	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) 4-Pole ATS required. 2) Provide bus sizing on Square D equipment. Job finalized 7/18/06.				
47225	06A0305	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
47226	06A0307	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
47227	06A0309	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Verify clearance in front of S.E.B. Job finalized 7/18/06.				
47228	06A0311	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Fire pump services switch located at end of switchboard. 2) Primary to XFMR undersized. 3) Eliminate 7th service switch. Job finalized 6/21/06.				

ADVISORY BOARD CALENDAR

June 14, 2006

Calendar #	Submission #	Type of Request	Status	Fee
47229	06A0313	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
47230	06A0315	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
47231	06A0317	Requested approval for the electric service equipment proposed to be installed	Hold	\$650.00
1) Normal f.p. disconnect undersized. 2) Normal f.p. disconnect must be in dedicated enclosure. 3) Service fuse distribution fused not coordinated. 4) Feeder size to ATS #3 not shown. Show 3P or 4P. 5) Provide generator room layout. Show loc. of f.p. switches. 6) Gen feeder to 'EMDP' undersized. 7) 'MSSA 52': provide code clearances. 8) Provide section views.				
47232	06A0319	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Feed to existing All City service switchboard undersized. 2) Verify available short circuit current at new 400A panel. Job finalized 6/26/06.				
47233	06A0321	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00

ADVISORY BOARD CALENDAR

June 14, 2006

Calendar #	Submission #	Type of Request	Status	Fee
47234	06A0303	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
47235	06A0287	Requested approval for the electric service equipment proposed to be installed	Hold	\$650.00
1) Fire pump must be fed from Con-Ed box. 2) Fuse types not provided for pullouts. 3) Remove neutral bond in 400 amp disconnect switch. 4) Provide elevator drawing of 1200A service switch.				
47236	06A0288	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
47237	06A0289	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
47238	06A0291	Requested approval for the electric service equipment proposed to be installed	Hold	\$650.00
One line missing.				

ADVISORY BOARD CALENDAR

June 14, 2006

Calendar #	Submission #	Type of Request	Status	Fee
47239	06A0302	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
47240	06A0296	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
47241	06A0298	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
47242	06A0300	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
47243	06A0304	Requested approval for the electric service equipment proposed to be installed	Hold	\$650.00
Fire pump feed must be taken from the Con-Ed box.				

ADVISORY BOARD CALENDAR

June 14, 2006

Calendar #	Submission #	Type of Request	Status	Fee
47244	06A0306	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Relocated 800 amp service switch.				
47245	06A0308	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
47246	06A0310	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
47247	06A0314	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
47248	06A0312	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00

ADVISORY BOARD CALENDAR

June 14, 2006

Calendar #	Submission #	Type of Request	Status	Fee
47249	06A0323	Requested approval for the electric service equipment proposed to be installed	Hold	\$650.00
1) Manufacturers cut sheets of equipment not provided. 2) Bus size in Con-Ed box not provided. 3) Verify length of service entrance conductors. 4) Provide supplemental ground. 5) Provide details of service room (elevations). 6) Provide signage in each service room.				
47250	06A0316	Requested approval for the electric service equipment proposed to be installed	Ok, but	\$650.00
Fire pump feeder undersized.				
47251	06A0318	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
47252	06A0322	Requested approval for the electric service equipment proposed to be installed	Hold	\$650.00
1) Key interlock scheme not provided. 2) No coordination between 3000A main and 3000A 2nd level breaker. Show 3rd level. 3) Confirm front accessible equipment . 4) Provide section views. 5) Provide code clearances in front of equipment.				
47253	06A0320	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00

ADVISORY BOARD CALENDAR

June 14, 2006

Calendar #	Submission #	Type of Request	Status	Fee
47254	,	Requesting permission to install a seventh service switch where one of the switches will power a fire pump.	Approved	\$0.00
47255	,,	Requesting permission to install a seventh service switch where one of the service switches powers a special service fire pump.	Approved	\$0.00
47256	,,,	Requesting concept approval to allow Schedule 80 non metallic conduit as a underground wiring method for service entrance conductors that will run approximately 100 feet into a building.	Approved	\$0.00
With the stipulation that all stup ups and elbows are metallic.				
47257	,,,,	Requesting permission to install overhead service entrance conductors in Schedule 80 non metallic conduit for three buildings(1-2 family and 2-3 family) located in a corrosive area, Far Rockaway. Queens.	Approved	\$0.00
47258	,,,,,	Requesting permission to install a second overhead service on the outside of eight single family dwellings to provide power for private street lighting, the services will not be grouped together signage will be provided at each service indicating where the other service is located.	Approved	\$350.00

ADVISORY BOARD CALENDAR

June 14, 2006

Calendar #	Submission #	Type of Request	Status	Fee
47259	*****	Requesting permission to install a 100 amp disconnect switch painted red, pad locked in the closed position and permanently labeled "fire alarm power supply do not disconnect" in lieu of an 90 amp fuse cut-out that will power a fire alarm system.	Approved	\$0.00
With the stipulation that approval is subject to other jurisdictions.				
47260	*****	Requesting permission to install kitchen counter receptacles 22 inches above the counter instead of the required 20 inches in a building that has 29 apartments.	Denied	\$0.00
47261	*****	Requesting permission to wire a fire alarm system that was filed under the old New York City Electrical Code Bulletin #134 and RS17-3A, RS17-5 of the New York City Building Code on a installation that was presently violated by the New York City Fire Department	Hold	\$0.00
Bulletin #134 is for the entire fire alarm system not partial. The buildings classification requires an entire fire alarm system not a partial system. "More information needed".				
47262	*****	Requesting permission to leave as installed a fire alarm fuse cut-out in a weatherproof enclosure mounted on the outside of a commercial building grouped together with the existing service equipment.	Approved	\$350.00
47263	*****	Requesting permission to leave as installed exhaust hoods connected to small appliance branch circuits in a multi dwelling with 80 apartments	Denied	\$350.00

ADVISORY BOARD CALENDAR

June 14, 2006

Calendar #	Submission #	Type of Request	Status	Fee
47264	*****	Requesting permission due to lack of space inside of the existing service room to install a new 800 amp service outside of the service room, signage will be provided at each service indicating where the other service is located.	Approved	\$350.00
47265	*****	Requesting permission to install a demand controller device in a residential dwelling where 2 apartments were combined into one, the existing feeders are undersized and the owner won't allow new feeders to be installed	Denied	\$0.00
Section 215.2(A)(1) requires that the feeder conductors shall have an ampacity not less than required to supply the load served. The feeder conductors shall be sized so that the maximum voltage drop at the last overcurrent device does not exceed 3% and the total maximum conductors to the last outlet does not exceed 5%.				
47266	*****	Requesting permission to replace the defective interior of a 3000 amp 120/208V service switch with a new interior	Approved	\$0.00
with the stipulation that the installation complies with Article 408 of the 2002 NEC and local amendments.				
47267	06A0324	Requested approval for use in New York City of your S217 Line-voltage Light Switch with low-voltage P564 DND/MUR/Chime in voltage separated double-gang box. Model/Series Numbers: S217 1R light switch, PN: 01-9603; P564 DND/MUR/Chime, PN: 01-9825.3.	Approved	\$200.00
Concept only				
47268	06A0325	Requested approval for use in New York City of your Low voltage lighting control system and/or European-style Wiring Devices for use in single residence. Model/Series Numbers: "My home Comfort Automation" Cat. and/or N4001, N4003, N4188GF, N44402, N4703 and N4803.	Denied	\$200.00
Product must be listed by a Nationally Recognized Testing Laboratory as a complete assembly.				

