

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Richard C. Visconti, R.A., Acting Commissioner
MEA 11-00-E

Report of Material and Equipment Acceptance Division

Manufacturer- ClimateMaster Inc., 7300 SW 44th Street, Oklahoma City, OK 73179.

Trade Name(s) -Roomate.

Product - Terminal Air Conditioners.

Pertinent Code Section(s) - 27-770, 27-777.

Prescribed Test(s) -RS 13-6 (ANSI B9.1), RS 13-11 (UL1995, CSA 236-M95).

Laboratory - Canadian Standards Association.

Test Report(s) - No. LR35557-112S, dated July 12, 1999.

Description - Vertical terminal air conditioners, with optional hot water, hydronic or electric heat. Units consist of a hermetic compressor, high pressure switch, coil (air cooled) or a shell and tube condenser (fluid cooled), and a blower (air cooled) or a fluid control valve (fluid cooled). Units may be ducted or free air discharge. R-22 is the refrigerant used for the system.

PRODUCT COVERED:

Vertical Terminal Air Conditioners, with optional hot water, hydronic or electric heat, Model VTA (12,18)(G,E)*, and Cabinet Models VTC (12,18)(G,E)(A,E,F,G,H,N)*, rated 208/230V ac or 265V ac, 60 Hz, 1 ph, Refrigerant 22.

Note: * - Denotes additional suffix letters may appear.

Model No.	Mfr.'s Specified Nominal Cooling Capacity BTUH
VTA/VTC12	15,100
VTA/VTC18	17,800

Recommendation - That the above described air conditioners, be accepted for indoor installation, when utilizing Refrigerant R22, under the following conditions:

1. All equipment shall be furnished with a permanently affixed metal tag stating that if installed in New York City within 100 feet of any dwelling unit window, that shall be compliance with all provisions of Section 27-770, as to maximum sound levels permitted for exterior mechanical equipment.
2. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.
3. Approval of electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation.

Final Acceptance

4/26/2000

Examined By

S.M. DiCiccio