

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found for use in accordance with the Report of the Material and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A., Commissioner

MEA 11-04-M
Report of Material and Equipment Acceptance Division

Manufacturer – Viscotes USA LLC., 18 Sidney Circle, Kenilworth, New Jersey 07033.

Trade Name – Fabric Banners/Mural.

Product – Fabric for flexsign.

Pertinent Code Sections – 27-499, 27-501, 27-506, 27-507, and TPPN #11/99.

Prescribed Test – RS 7-3 [NFPA 701(Test Method 2)].

Laboratory – The Govmark Organization, Inc.

Test Report – Report No. 246969-0 dated September 3, 2003.

Description – 100% polyester fabric material printed for use as banners, point of purchase, building banners, and murals. The fabric has a thickness of .15mm thru 2.0 mm and weight of 56 g/m² thru 545 g/m².

Recommendation - That the above material be accepted as meeting the flame resistance requirements of Section 27-596 and 27-507 of the Building Code, for use on flexsigns. The acceptance of this material is limited to flame resistance only. Structural and other requirements shall be in accordance with pertinent Building Code provisions and Technical Policy and Procedure Notice #11/99. All installations, uses and locations shall be in accordance with the New York City Building Code, specifically with Section 27-499 and 27-501, and the Zoning Resolution. All shipments and deliveries of such materials shall, in addition, be accompanied by a metal tag certifying that the materials shipped or delivered are equivalent to that tested and acceptable for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance Feb 27 / 04

Examined By S. Derfke