

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Material and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A., Commissioner
MEA 116-02-E

Report Materials and Equipment Acceptance Division

Manufacturer – Hill Phoenix, 1925 Ruffin Mill, Colonial Heights, VA 23834.

Trade Name – Hill Phoenix.

Product – Self-contained commercial refrigerated showcases.

Pertinent Code Section(s) – 27-771, 27-772, 27-777(f).

Prescribed Tests – RS 14-6 (UL 471).

Laboratory - Underwriters Laboratories, Inc.

Test Report – UL File SA1211, dated April 25, 27, 1995, October 6, 1998, and December 4, 1998.

Description – Self contained commercial refrigerated showcases, as tabulated below. These are display units with or without glass enclosure. They do not employ a defrost system. Units comprise on/off switches, refrigeration controllers, condensing units, junction boxes, and evaporators. Condensing units are equipped with compressors, starting capacitors, condensers, interior lighting and receivers.

PRODUCT COVERED

The following UL File SA1211, Volume 3, Report section cover the noted equipment:

Sec. 2, Issued April 25, 1995 - Self contained Models 02.5UMA4, 03UMA4.

Sec. 4, Issued April 27, 1995 - Self contained Model 05DMA4.

Sec. 11, Issued October 6, 1998 - Self contained Models OSI4A and OSIOA4.

Sec. 12, Issued December 4, 1998 - Self contained Models ONUA4,-47,-6,-71.

Recommendation - That the above described self contained refrigerated show cases, be accepted, under the following conditions:

1. Units shall be installed in accordance with manufacturer's instructions and New York City Electrical Code requirements.
2. Adequate supply of fresh air shall be provided into room or space enclosing equipment for ventilation.
3. The installation shall not interfere with accessibility for operation and servicing.
4. No flammable material (except electrical insulation) shall be located in the machine or wiring compartments unless specified.
5. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided for in Section 27-131 of the Building Code.
6. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation.

Final Acceptance 6/20/02
Examined by Stephen M. [Signature]