

CITY OF NEW YORK  
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Material and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A., Commissioner  
MEA 122-03-E

Report Materials and Equipment Acceptance Division

Manufacturer – Winiamando Inc., Asan City Korea for Winia USA Corp., 377 Rt. 17S, #216  
Hesbrouch Heights, NJ 07604

Trade Name – Winia/Hyundai.

Product – Split system air conditioning units.

Pertinent Code Section(s) – 27-770, 27-777.

Prescribed Tests – RS 13-6 (ANSI B9.1), RS 13-11 (UL 1995).

Laboratory – Intertek Testing Services, HK Ltd.

Test Report – JHK 02913-001, dated September 24, 2001; April 1, 2003.

Description – Split type air conditioners, made up of two indoor section and an outdoor section to be connected electrically and by refrigeration lines when installed. The unit is charged with refrigerant at factory and provided with terminal for permanent connection.

Indoor Unit	Outdoor Unit	Cooling Capacity BTUH
WSA/HSA-090	WSA/HSA-090	9,000
WSA/HSA-120	WSA/HSA-120	12,000
WSA/HSA-202	WSA/HSA-202	20,000
WSA/HSA-242	WSA/HSA-242	24,000
WMA/HMA-183	WMA/HMA-183	18,000
WMA/HMA-243	WMA/HMA-243	24,000

Recommendation - That the above described split system air conditioning units, be accepted, when utilizing Refrigerant R-22, under the following conditions:

1. All equipment shall be furnished with a permanently affixed metal tag stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770, as to maximum sound levels permitted for exterior mechanical equipment.
2. If air conditioning system is installed in combination with a furnace then the furnace must be MEA accepted.
3. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided for in Section 27-131 of the Building Code.
4. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation.

Final Acceptance 9/25/03

Examined by Shyr M. J...