



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 132-06-E

Manufacturer: Carrier Corporation, 7310 West Morris Street, Indianapolis, Indiana 46231

Trade Name(s): Carrier

Product: Heat pump condensing sections

Pertinent Code Section(s): 27-770, 27-777

Prescribed Test(s): RS 13-11B (ANSI B9.1), RS 13-13 (UL 1995)

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): UL File SA11583, dated January 5, 2006

Description: Heat pump condensing sections, model 25HPA5, designed for outdoor installation. R-410A is the refrigerant used for the system. Unit consists of a scroll compressor, air cooled condenser with fan, electrically operated reversing valve and safety controls. Units, with model numbers, heating and cooling capacities, are listed below:

Model No.	Mfr.'s Specified Cooling Capacity (BTUH)	Mfr.'s Specified Heating Capacity Range (BTUH)
25HPA518*00*	17,800	10,400- 18,000
25HPA524*00*	23,600	14,000-23,800
25HPA530*00*	29,200	17,200-29,400
25HPA536*00*	36,000	19,800-34,000
25HPA542*00*	42,000	25,400-42,000
25HPA548*00*	48,000	30,000-48,000
25HPA560*00*	60,000	37,000-59,500

* A= Standard Unit, C= Coastal Unit

* 1= 575 volt- 3 phase, 3= 208/230v-1 phase, 5= 208/230 v- 3 phase, 6= 460v- 3 phase

Terms and Conditions: The above-described heat pump air-cooled condensing units are accepted under the following conditions:

1. Units shall use only Refrigerant R-410A.
2. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.
3. A tag must be permanently affixed to the equipment stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770 as to maximum sound levels permitted for exterior mechanical equipment.
4. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
5. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.

Note: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance October 26, 2006

Examined By Siun DerPhulan