



NYC Department of Buildings
 280 Broadway, New York, NY 10007
 Patricia Lancaster, FAIA, Commissioner
 (212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 144-05-E Vol.1

Manufacturer: Guangdong Chicago Air Conditioning Co. P.O. Box 1559 Oh Fallon, MO 63366

Trade Name(s): Hiseer

Product: Room Air Conditioning Units

Pertinent Code Section(s): 27-770, 27-777

Prescribed Test(s): RS 13-6 (ANSI B9.1), RS 13-11 (UL 1995).

Laboratory: Underwriters Laboratories Inc.

Test Report(s): File SA 12793, dated August 2, 2003.

Description – Room air conditioning units, for indoor installation and for use with ductwork connected to conditioning space. R-22 is the refrigerant used for the system. Unit consists of hermetically sealed compressors, air-cooled condenser or water-cooled evaporator and blower and controls. Units are provided with automatic pressure limiting device set at 360psi maximum. Units may be provided with field or factory installed electric heaters ranging from 16kw to 28kw. Units, with model numbers and nominal cooling capacities, are listed below:

Wall Mount Min Split System

Model Numbers	Capacity
WMMS-09K-01A, WMMS-12K-01A, WMMS-18K-01B, WMMS-24K-01B, WMMS-09K-02A, WMMS-12K-02A, WMMS-18K-02B, WMMS-24K-02B	9,000-24,000 BTU/H
WMMS-09E-01A, WMMS-12E-01A, WMMS-18E-01B, WMMS-24E-01B, WMMS-09E-02A, WMMS-12E-02A, WMMS-18E-02B, WMMS-24E-02B	9,000-24,000 BTU/H
WMMS-09C-01A, WMMS-12C-01A, WMMS-18C-01B, WMMS-24C-01B, WMMS-09C-02A, WMMS-12C-02A, WMMS-18C-02B, WMMS-24C-02B.	9,000- 24,000BTU/H
HORIZONTAL VENT CONDENSER	CAPACITY

SHCR-09K-01A, SHCR-12K-01A, SHCR-18K-01B, SHCR-24K-01B, SHCR-09K-02A, SHCR-12K-02A, SHCR-18K-02B, SHCR-24K-02B	9,000- 24,000BTU/H
PORTABLE AIRCONDITIONER/HEATER COOLING AND HEATER	CAPACITY
PACH-07K-01A, PACH-07K-02A, PACH-07K-03A, PACH-09K-01A, PACH-09K-02A, PACH-09K-03A, PACH-12K-01A, PACH-12K-01A, PACH-12K-02A, PACH-12K-03A	7,000- 12,000BTU/H
PACKAGED TERMINAL AIR CONDITIONER COOLING HEATING	
MODEL NUMBERS	CAPACITY
PTAC-09K-01B, PTAC-12K-01B, PTAC-15K-01B, PTAC-09K-02B, PTAC-12K-02B, PTAC-15K-02B, PTHP-09K-03B, PTHP-12K-03B, PTHP-15K-03B, PTHP-09K-04B, PTHP-12K-04B, PTHP-15K-04B.	9,000- 15,000BTU/H

Terms and Conditions: that the above described air conditioning units shall be accepted for indoor installation, when utilizing refrigerant R-22, under the following conditions:

1. All equipment shall be furnished with a permanently affixed metal tag stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770, as to maximum sound levels permitted for exterior mechanical equipment.
2. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered are equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.
3. Approval of all electrical equipment, apparatus, materials, and devices shall be obtained from the Department before installation.

Final Acceptance 6/12/06
Examined By Stephen. Mason