



# Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Robert D. LiMandri, Acting Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

## MEA 144-07-E

**Manufacturer:** Garland Commercial Ranges Limited  
1177 Kamato Road  
Mississauga, Ontario L4W 1X4  
CANADA

**Trade Name(s):** Garland

**Product:** Electric griddle for commercial use  
MEA Index #150-120 – Cooking Appliances

**Pertinent Code Section(s):** Subchapter 14

**Prescribed Test(s):** RS 14-6 (ANSI/UL 197)

**Laboratory:** CSA International (Canadian Standards Association)

**Test Report(s):** No. 151344-1174359 dated August 20, 2001 and revised February 6, 2007.

**Description:** Electric griddles for commercial cooking use, permanent connection to 208 or 240Vac, 60Hz. Units are comprised of solid a metal cooking surface, electronic thermostats; on/off and pilot switches and electric heating elements. Units are equipped with terminal blocks and circuit breakers. Models are tabulated below:

| Model No. | Description   | Load     |
|-----------|---|----------|
| ECG-24R   | 24" wide Griddle with Two individually controlled element banks   | 8.6 kW   |
| ECG-36R   | 36" wide Griddle with Three individually controlled element banks | 12.90 kW |
| ECG-48R   | 48" wide Griddle with Four individually controlled element banks  | 17.20 kW |
| ECG-60R   | 60" wide Griddle with Five individually controlled element banks  | 21.50 kW |
| ECG-72R   | 72" wide Griddle with Six individually controlled element banks   | 25.80 kW |

**Terms and Conditions:** The above electric griddles are accepted under the following conditions:

1. Units shall be installed in accordance with manufacturer's instructions and New York City Electrical, Building and Fire Codes.
2. Minimum installed clearances from combustible construction shall be in accordance with RS 14-15 of the New York City Building Code.
3. Installation shall not obstruct access for operation and servicing.
4. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
5. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
6. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

**Note:** In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance August 18, 2008  
Examined By Donald [Signature]