



# Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

## MEA 145-05-E

**Manufacturer:** Liebert Corporation, 1050 Dearborn Drive, Columbus, Ohio 43229.

**Trade Name(s):** Liebert.

**Product:** Computer room air conditioning units.

**Pertinent Code Section(s):** 27-770, 27-777.

**Prescribed Test(s):** RS 13-11(UL 1995), RS 13-6 (ANSI B9.1).

**Laboratory:** Canadian Standard International.

**Test Report(s):** No. 1633124 dated June 10, 2005.

**Description** – Computer room air conditioning as listed below:

Model No.*	Mfr.'s Specified Nominal Cooling Capacity kW
XDC160A, G, W	160
DSO28	28
DSO35	35
DSO42	42

Note: Model number may have variable prefix and/or suffix digits.

**Terms and Conditions:** That the above outdoor air-cooled condensers, be accepted under the following conditions:

1. All equipment shall be furnished with a permanently affixed metal tag stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770, as to maximum sound levels permitted for exterior mechanical equipment.
2. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.
3. Approval of electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation.

Final Acceptance 3/24/06  
Examined by Shyam. Prasad