



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Robert D. LiMandri, Acting Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 148-08-E

Manufacturer: Hearth & Home Technologies Inc.
1445 North Highway
Colville, WA 99114

Trade Name(s): Hearth & Home Technologies

Product: Gas-fired, direct vent room heaters
MEA Index #410-70 – Heaters

Pertinent Code Section(s): 27-800, RS 14-2 (ANSI Z223.1)

Prescribed Test(s): RS 14-6 (ANSI Z21.88a-2000)

Laboratory: Omni-Test Laboratories, Inc.

Test Report(s): 061-S-35-5 issued December 2001.
061-S-64-5 issued June 2005.
061-S-19-5 issued June 13, 2001.
061-S24-5 issued January 2002.

Description: Gas-fired, direct vent free-standing room heater appliances designed to provide heating and to enhance the aesthetics of a room.

Product Covered

DOVRE GARNET – DV250 (NG 12,000 BTU-minimum to 17,000 BTU-maximum).

CASTILE – (NG 22,000 BTU-minimum to 31,000 BTU-maximum)

SAPPHIRE (formerly Dovre 425TR) – (NG 21,000 BTU-minimum to 30,000 BTU-maximum)

SAPPHIRE (formerly Dovre 425TR) – (NG 18,000 BTU-minimum to 26,000 BTU-maximum)

TOPAZ (formerly DV450) – (NG 26,500 BTU-minimum to 39,500 BTU-maximum)

Terms and Conditions: The above-described gas-fired, vented appliances are accepted for decorative heating operation under the following conditions:

1. Units shall use natural gas only.
2. Units shall be installed indoors only.
3. Venting of the units is subject to Section 27-879 of the New York City Building Code.
4. Units shall not be installed behind doors, in an alcove or at locations where curtains or drapes can come into contact with them.
5. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Control Advisory Board before installation.
6. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
7. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Note: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance August 7, 2008.
Examined By Donald [Signature]