

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, F.A.I.A., Commissioner
MEA155-04-E

Report of Material and Equipment Acceptance Division

Manufacturer - Rheem Manufacturing Company, P.O. Box 17010, Fort Smith, AR 72917-7010. Trade Name(s) - Ruud.

Product - Condensing and compressor units.

Pertinent Code Section(s) - 27-770, 27-777.

Prescribed Test(s) -RS 13-6 (ANSI B9.1), RS 13-11 (UL 1995).

Laboratory- Underwriters Laboratories Inc.

Test Report(s) - File SA3930, dated May 16, 1994, revised January 2, 2002.

Description - Outdoor air-cooled condenser used for refrigeration and air conditioning systems. This is a component comprising of a metal enclosure, condenser coil, fan and fan motor and appropriate controls. Units, with cooling capacities are listed below:

Model No.	Mfr.'s Specified Nominal Cooling Capacity Tons
RAWE079	6.5
RAWE091	7.5

Recommendation - That the above outdoor air-cooled condensers be accepted, under the following conditions:

1. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.
2. All equipment shall be furnished with a permanently affixed metal tag stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be provisions with all provisions of Section 27-770, as to maximum sound levels permitted for exterior mechanical equipment.
3. Approval of electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation.

Final Acceptance 7/27/04

Examined By Stephen J. Green