



## Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
 280 Broadway, New York, NY 10007  
 Patricia Lancaster, FAIA, Commissioner  
 (212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

### MEA 158-05-E

**Manufacturer:** Winia Mando Inc., Asan City Korea for Winia USA Corp., 377 Rt. 17S, #216 Hesbrouch Heights, NJ 07604.

**Trade Name(s):** Winia/ Hyundai

**Product:** Split system air conditioning units.

**Pertinent Code Section(s):** 27-770, 27-777

**Prescribed Test(s):** RS 13-6 (ANSI B9.1), RS 13-11 (UL 1995).

**Laboratory:** Intertek Testing Services, HK Ltd.

**Test Report(s):** J11K04000523-715, dated January 31, 2005.

**Description –** Split type air conditioners, made up of two indoor sections and an outdoor section to be connected electrically and by refrigeration lines when installed. The unit is charged with refrigerant at factory and provided with terminal for permanent connection.

Type	Function	Model Numbers	Model Numbers	ETL	BTU
	Cooling & Heat Pump	WSH-120AL	HSH-120AL	JHK01*464-001	12000
		WSH-185AL	HSH-185AL	JHK04*550-301	18000
Wall Mounted Multi-Split	Cooling & Heat Pump	WMH-183AL	HMH-183AL	JHK03*791-001	9000 x 2
		WMH-243AL	HMH-243AL	JHK03*791-001	12000 x 2
Floor Standing	Cooling & Heat Pump	WPH-305AL	HPH-305AL	JHK04*523-301	30000

**Terms and Conditions:** The above described split system air conditioning units are accepted, when utilizing Refrigerant R-22, under the following conditions:

1. All equipment shall be furnished with a permanently affixed metal tag stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770, as to maximum sound levels permitted for exterior mechanical equipment.
2. If air conditioning system is installed in combination with a furnace then the furnace must be MEA accepted.
3. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the Building Code.
4. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department before installation.

Final Acceptance 4/24/06  
Examined by Shyam M. Jaiswal