



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Robert D. LiMandri, Acting Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 163-08-M

Manufacturer: Circle Graphics, Inc.
120 9th Avenue
Longmont, Colorado 80501

Trade Name(s): Eco-Flexx

Product: Flame-retardant polyethylene fabric for flexible signage
MEA Index #30-10 – Flex Signs

Pertinent Code Section(s): 27-499, 27-501, 27-506, 27-507, and TPPN #11/99

Prescribed Test(s): RS 73 (NFPA 701 – Test Method 2)

Laboratory: SGS U.S. Testing Company, Inc.

Test Report(s): Report No. 177:009894 dated January 30, 2008.

Description: The material is a flame-retardant, reinforced polyethylene fabric. The material is coated with a flame-retardant acrylic coating. The material is 5.0 mil thick polyethylene web with white, print-receptive coating. The product is used for outdoor signage (banners, signs and billboards).

Terms and Conditions: The above-described material is accepted with the following conditions:

1. The acceptance of this material is limited to flame resistance.
2. Structural and other requirements shall be in accordance with pertinent Building Code provisions and Technical Policy and Procedure Notice #11/99.

3. All installations, uses and locations shall be in accordance with the New York City Building Code, specifically with Section 27-499 and 27-501, and the Zoning Resolution.
4. All shipments and deliveries of such material shall be provided with a label, suitably placed, certifying that the material shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Note: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance June 20, 2008

Examined By Siun Derfliden