



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 172-04-E

Manufacturer: Rheem Manufacturing Co., P.O. Box 17010, Fort Smith, AR 72917-7010

Trade Name(s): Rheem

Product: Outdoor air-cooled condensing and compressor units.

Pertinent Code Section(s): 27-770, 27-777

Prescribed Test(s): RS 13-6 (ANSI B9.1), RS 13-11 (CSA C22.2, No. 236; UL 1995).

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): No. SA7930, dated January 30, 2004.

Description – Outdoor air-cooled condensing and compressor units used for refrigeration and air conditioning systems. This is a component comprised of a condenser coil, fan motor and appropriate controls. Units with cooling capacities are listed below:

Model No.	Mfr.'s Specified Nominal Cooling Capacity, Tons
RAMC018*	1.5
RAMC024*	2.0
RAMC030*	2.5
RAMC036*	3.0
RAMC042*	3.5
RAMC048*	4.0
RAMC060*	5.0

* Model designation may be suffixed

Terms and Conditions: The above outdoor air-cooled condensers are accepted under the following conditions:

1. All equipment shall be furnished with a permanently affixed metal tag stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770 as to maximum sound levels permitted for exterior mechanical equipment.
2. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the New York City Building Code.
3. Approval of electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
4. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.

Note: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance 11/14/06

Examined By Shyam Prasad