



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 176-07-E

Manufacturer: Eair LLC, 12201 N.W. 107th Avenue, Medley, FL 33178

Trade Name(s): ComfortStar

Product: Packaged, terminal room air conditioner

Pertinent Code Section(s): 27-770, 27-777

Prescribed Test(s): RS 13-11B (ANSI B9.1), RS 13-11A (UL 1995)

Laboratory: Intertek Testing Services

Test Report(s): JGZ05*015-301, dated January 6, 2007.

Description: The packaged, terminal room air conditioners covered in this report are cord-connected units designed for indoor use only. Units employ cooling only or heat pump with electric heat, and may or may not be provided with a remote control.

Model No.	Nominal Capacity (TONS)
GD(H)9000(H)	3/4
GD(H)12000(H)	1
GD(H)15000(H)	1-1/4

Terms and Conditions: The above-described air-conditioning units are accepted under the following conditions:

1. Units are for residential use only.
2. Units shall use only Refrigerant R-410A.
3. If utilized for residence heating, the circulatory air system shall have (a) one register or grille without closeable shutters and the duct leading thereto shall be without a damper, or (b) dampers and shutter within the system that shall be constructed or controlled so as to prevent closure beyond 80 percent of the gross duct area at all times.
4. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
5. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
6. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance 8/1/07

Examined By 