

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Satish K. Babbar, R.A., Acting Commissioner

**MEA 18-00-M
Report of Material and Equipment Acceptance Division**

Manufacturer - GAF Materials Corporation, 1361 Alps Road, Wayne, NJ 07470.

Trade Name - GAF.

Product - Asphalt coated shingle roof coverings. Royal Sovereign, Grand Sequoia®, Grand Canyon™, and Country Mansion™

Pertinent Code Section(s) - 27-337.

Prescribed Test(s) - RS 5-10 (ASTM E108).

Laboratory - Underwriters Laboratories Inc.

Test Report(s) - UL File R21190NK17310 dated April 30, 1991.

Description - Fiberglass reinforced, granule surfaced, asphalt coated shingles in a nominal size of:

Royal Sovereign - 12" x 36"

Grand Sequoia - 17" x 40"

Grand Canyon - 17" x 40"

Country Mansion - 17" x 40"

All are intended for use as a roof covering. They are all Class A rated.

Recommendation - That the above asphalt roof covering materials be classified as Class A in accordance with Section 27-337 of the Building Code.

All shipments of these shingles shall be labeled indicating that the materials shipped are equivalent to those tested and are acceptable for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance AUG 24 2000

Examined By S Derkudam