

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

**Patricia J. Lancaster, F.A.I.A., Commissioner
MEA 197-04-E**

Report of Material and Equipment Acceptance Division

Manufacturer – ICECO, P.O. Box 17010, Fort Smith, AR 72917-7010.

Trade Name(s) – Weatherking.

Product –Condensing and compressor units.

Pertinent Code Section(s) – 27-770, 27-777.

Prescribed Test(s) -RS 13-6 (ANSI B9.10), RS 13-11 (UL 1995).

Laboratory – Underwriters Laboratories Inc.

Test Report(s) – File SA7930, dated January 30, 2004.

Description – Outdoor air cooled condenser used for refrigeration and air conditioning systems. This is a component comprising of a metal enclosure, condenser coil, fan and fan motor and appropriate controls. Units, with cooling capacities are listed below:

Model No.	Mfr.'s Specified Nominal Cooling Capacity TONS
10AJB18	1.5
10AJB24	2.0
10AJB30	2.5
10AJB36	3.0
10AJB42	3.5
10AJB48	4.0
10AJB60	5.0

Recommendation - That the above outdoor air cooled condensers be accepted, under the following conditions:

- 1. All shipments and deliveries of such equipment shall be accompanied by a certificate or label certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.**
- 2. All equipment shall be furnished with a permanently affixed metal tag stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770, as to maximum sound levels permitted for exterior mechanical equipment.**
- 3. Approval of electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation.**

Final Acceptance 7/27/04

Examined By Shyam. R. Das