

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A., Commissioner

MEA 20-03-E
Report of Material and Equipment Acceptance Division

Manufacturer – McQuay International, 4900 Technology Park Boulevard, Auburn, New York 13021.

Trade Name(s) – Comfortpac.

Product – Room air conditioning units.

Pertinent Code Section(s) -27-770, 27-777.

Prescribed Test(s) - RS 13-6 (ANSI B9.1), RS 13-12 (UL 484, UL 1995).

Laboratory – ITS International and ETL Testing Laboratories.

Test Reports – Report No. 01106103 dated June 8, 2001 and December 4, 2002.

Description – Packaged, room air conditioning units, designed for thru-the-wall installation. R-22 is the refrigerant used for the system. Unit consists of compressor, air cooled condenser with fan, capillary tubing, evaporator coil, controls, and electric heating element. Units, with model numbers and nominal cooling capacities, are listed below.

| Model No. | Mfr.'s Specified Nominal Cooling Capacities BTUH |
|-----------|--|
| PTAC07 | 7,000 |
| PTAC09 | 9,000 |
| PTAC12 | 12,000 |
| PTAC15 | 15,000 |

Note: Different suffixes denote variation for voltages.

Recommendation - That the above described packaged room air conditioning units be accepted when utilizing Refrigerant R-22, under the following conditions:

1. All equipment shall be furnished with a permanently affixed metal tag stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770, subdivision 4, as to maximum sound levels permitted for exterior mechanical equipment.
2. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.
3. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the of Electrical Control before installation. provisions of law, but have not been tested in conjunction with this application.

Final Acceptance March/28/03

Examined By S Derphudom