

Report of Materials and Equipment Acceptance Division

NYC Department of Buildings 280 Broadway, New York, NY 10007 Patricia Lancaster, FAIA, Commissioner (212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 209-82-M Vol. 4

Manufacturer: Thermafiber, Inc.

3711 Mill Street Wabash, IN 46992

Trade Name(s): Thermafiber Curtain Wall and Safing Insulations

Product: Mineral-fiber thermal insulation material

Pertinent Code Section(s): 27-232, 27-335.1

Prescribed Test(s): RS 5-5 (ASTM E84), Toxicity

Laboratory: Underwriters Laboratories, Inc.

United States Testing Company, Inc.

Test Report(s): UL File R4643, dated January 22, 1969, October 8,

1970, August 31, 1971, May 26, 1977 and

February 16, 1983.

U.S. Testing: No. 4037 dated July 30, 1982.

Description: Semi-rigid thermal curtain wall insulation blanket material in 1-inch to 6-inch thickness in ½-inch increments and in pounds per cubic foot densities, as follows, corresponding to factory designation numbers: 4.0 (CW/40), 6.0 (CW/70), and 8.0 (CW/90).

Safing Insulation: Semi-rigid thermal insulation felt, 4 pounds per cubic foot density, 4-inch thickness.

Flame Spread Rating – unfaced 0 (max.)
Flame Spread Rating – faced: 25 (max.)
Smoke Developed Rating: 0 (max.)

Terms and Conditions: The above-described mineral-fiber thermal insulation material is accepted under the following conditions:

- 1. The material may be used in either new or existing combustible or noncombustible construction.
- 2. This acceptance shall not be construed to provide a fire-resistance rating or an assembly comprising the insulation, in which entire assembly shall be required to be tested under ASTM E119 to determine the fire-resistance rating.
- 3. All shipments and deliveries of such material shall be provided with a label, suitably placed, certifying that the material shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance January 16,2008

Examined By: Seun Derschudam