

CITY OF NEW YORK  
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A., Commissioner

MEA 221-03-E  
Report of Material and Equipment Acceptance Division

Manufacturer – Wade Ceramics Incorporated, 2005 Fortune Drive, Winchester Industrial Park, Winchester KY 40391.

Trade Name – Wade Ceramics.

Product – Gas fired decorative log appliance.

Pertinent Code Section(s) – 27-800.

Prescribed Test(s) - RS 14-6 (ANSI Z21.60-1996).

Laboratory – Omni-Test Laboratories Inc.

Test Report(s) – No. 240-L-01-5 dated July 2002.

Description – Gas fired decorative log appliance designed to provide supplemental heating and to enhance the aesthetics of a room. The logs are ceramic fibers and are designed to be used in a vented fireplace. Model designations and input BTU ratings are as follows:

Model No	BTUH
HCA-24	45,000 – 67,000
MPF-18	35,000 – 53,000
MPF-24	35,000 – 53,000
MVO-18	35,000 – 53,000
MVO-24	35,000 – 53,000
SBJ-18	23,000 – 36,000
SBJ-24	23,000 – 36,000
SMA-18	23,000 – 36,000
SMA-24	23,000 – 36,000
VFR-18	23,000 – 36,000
VFR-24	23,000 – 36,000
VTD-18	35,000 – 53,000
VTD-24	35,000 – 53,000

Recommendation - That the above described gas fired log appliance, be accepted for use in vented fireplaces only, for decorative heating operation on natural gas and for indoor installation only with combustion air and required ventilation air provided. Venting of the fireplace is subject to Section 27-879 of the Building Code. Approval of electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance 9/25/03

Examined By Shya Javed