



NYC Department of Buildings
 280 Broadway, New York, NY 10007
 Patricia Lancaster, FAIA, Commissioner
 (212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 251-06-E

Manufacturer: Trane Company. 187 Cotton Belt Parkway
 McGregor, TX 76657

Trade Name(s): Trane

Product: Packaged water source heat pump units.

Pertinent Code Section(s): 27-777

Prescribed Test(s): RS 13-6 (ANSI B9.1) RS 13-13 (UL 1995)

Laboratory: Intertek Testing Services

Test Report(s): File No. 3036496-0001, dated February 24, 2002.

Description – Packaged water source heat pump units, designed for indoor installation. R-22 is the refrigerant used for the system. Unit comprises hermetically sealed compressor, tube-in-tube type water cooled condenser with piping connections, evaporator, expansion valve and controls. An electrically operated reversing valve is provided to initiate the reverse heat cycle. Units, with model numbers and heating/cooling capacities, are listed below:

Model No.	Mfr.'s Specified Nominal Cooling Capacity BTUH	Mfr.'s Specified Nominal Heating Capacity BTUH
GETB009	9000	9000
GETB012	12000	12000
GETB015	15000	15000
GETB018	18000	18000
GETB024	24000	24000
GETB036	36000	36000

Terms and Conditions: That the above described water source heat pump units, in conjunction with compatible heat rejection equipment such as a cooling tower, be accepted for indoor installation only, using refrigerant R-22, under the following conditions:

1. Cooling tower or other compatible outdoor heat rejection equipment, if installed within 100 feet of any dwelling unit window, complies with all provisions of Section 27-770, Subdivision 4, add to maximum sound levels permitted for exterior mechanical equipment.
2. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and acceptable for use as provided for in Section 27-131 of the Building Code.
3. Approval of all electrical equipment, apparatus, materials, and devices shall be obtained from the Department before installation.

Final Acceptance

6/20/06

Examined By

Sam Gray