



# Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

## MEA 26-07-E

**Manufacturer:** Rheem Manufacturing Co., P.O. Box 17010, Fort Smith, AR 72917

**Trade Name(s):** Rheem, Ruud, Weatherking, Thermal Zone

**Product:** Heat pump units

**Pertinent Code Section(s):** 27-770, 27-777

**Prescribed Test(s):** RS 13-11B (ANSI B9.1), RS 13-11A (UL 1995), RS 14-6 (ANSI Z21.47)

**Laboratory:** Underwriters Laboratories, Inc.

**Test Report(s):** File SA7930 dated March 30, 2004, revised September 7, 2004

**Description:** Packaged heat pumps, Model 13QJA, designed for outdoor installation. R-22 is the refrigerant used for the system. Unit is comprised of air-cooled condenser, hermetic-sealed compressor, expansion valve, evaporator coil and controls. An electrically operated reversing valve is provided to initiate the reverse cycle. Unit is provided with an internal relief assembly within the compressor. Units, with model numbers, heating and cooling capacities, are listed below:

Model No.	Mfr's Specified Nominal Cooling Capacity (BTUH)	Mfr's Specified Nominal Heating Capacity (BTUH)
13QJA24*	24,000	24,000
13QJA30*	30,000	28,800
13QJA36*	36,000	36,000
13QJA42*	42,000	40,500
13QJA48*	48,000	47,000
13QJA60*	60,000	57,500

\*Denotes additional characters in model numbers

**Terms and Conditions:** The above-described heat pump units are accepted under the following conditions:

1. Units shall be installed outdoors only.
2. Units shall use Refrigerant R-22 only.
3. If utilized for residence heating, the circulatory air system shall have (a) one register or grille without closeable shutters and the duct leading thereto shall be without a damper, or (b) dampers and shutter within the system that shall be constructed or controlled so as to prevent closure beyond 80 percent of the gross duct area at all times.
4. A tag must be permanently affixed to the equipment stating that if installed in New York City within 100 feet of any dwelling window, there shall be compliance with all provisions of Section 27-770, as to maximum sound levels permitted for exterior mechanical equipment.
5. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
6. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
7. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance 4/30/07

Examined By Shyam. [Signature]