

CITY OF NEW YORK  
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A., Commissioner

MEA 270-03-M  
Report of Material and Equipment Acceptance Division

Manufacturer – Kover Corporation, 11205 NW 131<sup>st</sup> Street, Miami, Florida 33178.

Trade Name(s) – Elite .

Product - PVC coated fabric for flexsign.

Pertinent Code Section(s) - 27-499, 27-501, 27-507, and TPPN #11/99.

Prescribed Test(s) - RS 7-3 [NFPA 701 (Test Method 2)].

Laboratory – Omega Point Laboratories Inc.

Test Report(s) – Omega Project No. 16782-115030 dated July 17, 2003.

Description – Flexible substrate for solvent digital printing, designated Elite, intended for use of signs and billboard advertisements. The material has 13.5-ounces/square yard.

Recommendation - That the above material be accepted as meeting the flame resistance requirements of Section 27-506 and 27-507 of the Building Code, for use on flex signs. The acceptance of this material is limited to flame resistance only. Structural and other requirements shall be in accordance with pertinent Building Code provisions and Technical Policy and Procedure Notice #11/99. All installations, uses and locations shall be in accordance with the New York City Building Code, specifically with Section 27-499 and 27-501, and the Zoning Resolution. All shipments and deliveries of such materials shall, in addition, be accompanied by a tag, certifying that the materials shipped or delivered are equivalent to those tested and acceptable for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance Sep/24/03

Examined By S DesRudam