

## Report of Materials and Equipment Acceptance Division

NYC Department of Buildings 280 Broadway, New York, NY 10007 Patricia Lancaster, FAIA, Commissioner (212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

## <u>MEA 305-06-M</u>

Manufacturer:	Protan. P.O. Box 420, Brakeroya N-3002 Drammen, Norway. N-3002 Drammen, Norway
Trade Name(s):	Quality 482
Product:	PVC coated fabric for covering buildings
Pertinent Code Section(s):	27-514, 27-499, 27-801, 27-506, 27-507
Prescribed Test(s):	RS 7-3 [NFPA 701(test method 2)]
Laboratory:	SGS US Testing Company, Inc.
Test Report(s):	Report # 16617-R1 Dated 09/23/02 Report# 16617 Dated 03/29/02

**Description** – Polyester coated woven fabric known as Protan Quality 482 is suitable for covering steel frame building

**Terms and Conditions:** That the above material be accepted as meeting the flame resistance requirements of Section 27-506 and 27-507 of the Building Code, for use on flex signs. The acceptance of this material is limited to flame resistance only. Structural and other requirements shall be in accordance with pertinent Building Code provisions and Technical Policy and Procedure Notice # 11/99. All installations, uses, and locations shall be in accordance with the New York City Building Code, specifically with Section 27-499 and 27-501, and the Zoning Resolution. All shipments and deliveries of such materials shall, in addition, be accompanied by a tag, certifying that the materials shipped or delivered is equivalent to those tested and acceptance for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance May 23, 2006 Examined By Sun Derphidam