

NYC Department of Buildings 280 Broadway, New York, NY 10007 Patricia Lancaster, FAIA, Commissioner (212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 337-07-E

| Manufacturer: | The Delfield Company, 980 South Isabella Road, Mt. Pleasant, Michigan 48858 | | |
|----------------------------|--|--|--|
| Trade Name(s): | Shelleymatic, Shelleyspeed, Versa Drawer | | |
| Product: | Commercial refrigerators & freezers (remote units) MEA Index #600 – Refrigerator Systems & Freezers | | |
| Pertinent Code Section(s): | 27-770, 27-777 | | |
| Prescribed Test(s): | RS 14-6 (UL 471) | | |
| Laboratory: | Underwriters Laboratories, Inc. | | |
| Test Report(s): | File SA4769 issued September 24, 1982. | | |

Description: Appliances are remote-control, cord-connected commercial refrigerators intended for connection to a 120 VAC, 60 Hz, single-phase supply source. The units have an onboard compressor and onboard refrigerating circuit. All models are intended to be elevated on legs. The units are equipped with air-cooled condensers, and the refrigeration circuits have capillary tubing.

Units with model numbers are provided on the following page.

| Models | File | Vol/Section | Standard |
|--|--------|-------------|----------|
| Remote Commercial Freezers – Model 13 with or without prefix F, followed by suffix BR or WR followed by suffix 18 through 54, with or without suffix -28 or -32. | SA4769 | V1, S12 | UL 471 |
| Remote Commercial Refrigerators – Model 28 with or without prefix F, followed by suffix 18 through 108, with or without additional suffix numbers or letters. | SA4769 | V1, S14 | UL 471 |
| Remote Commercial Freezers – Model 27 with or without prefix F, followed by 18 through 78, with or without additional suffix numbers or letters. | SA4769 | V1, S26 | UL 471 |
| Remote Commercial Refrigerators – Model 17 with or without prefix F, followed by suffix R, followed by suffix 18 through 108, with or without additional suffix numbers or letters. | SA4769 | V1, S14 | UL 471 |
| Remote Commercial Refrigerators – Model 18 with or without prefix F, followed by suffix WR, followed by suffix 18 through 108, with or without additional suffix numbers or letters. | SA4769 | V1, S14 | UL 471 |
| Remote Commercial Refrigerators – Model 18 with or without prefix F, followed by suffix DR, MR, RR or SR, followed by suffix 18 through 108, with or without additional suffix numbers or letters. | SA4769 | V1, S44 | UL 471 |
| Remote Commercial Freezers – Model 18FR with or without prefix F, followed by 18 through 78, with or without additional suffix numbers or letters. | SA4769 | V1, S26 | UL 471 |
| Remote Commercial Refrigerators and / or Freezers – Models 81, 82 or 86, followed by suffixes 14 through 144, with or without suffixes -1 through -6 or N, or prefix N, with or without additional suffix -B or -BR, with final suffix -R. | SA4769 | V1, S20 | UL 471 |
| Remote Commercial Refrigerators and / or Freezers – Model 81, with or without suffix 1 through 6, followed by suffix -31 through -138, with suffix FA, followed by suffix R. | SA4769 | V1, S55 | UL 471 |
| Remote Commercial Refrigerators – Models 5 and 15, with or without prefix F, followed by suffix H, M, P or S, followed by suffix R, followed by suffix 36, 48, 60, or 72, with or without suffix D or N. | SA4769 | V1, S23 | UL 471 |

Terms and Conditions: The above-described commercial refrigerators are accepted under the following conditions:

- 1. Units shall be installed in accordance with manufacturer's instructions and New York City Electrical Code requirements.
- 2. Adequate supply of fresh air for ventilation shall be provided into room or space enclosing equipment.
- 3. The installation shall not obstruct access for operation and servicing.
- 4. No flammable material (except electrical insulation) shall be located in the machine or wiring compartments unless specified.
- 5. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
- 6. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
- All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance March 14, 2008 Examined by Shyam Prasad (D)