

CITY OF NEW YORK  
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Material and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A., Commissioner  
MEA 34-03-E

Report of Material and Equipment Acceptance Division

Manufacturer- Rheem Manufacturing Company for RUUD, P.O. Box 17010,  
Fort Smith, AR 72917.

Trade Name - RUUD.

Product - Condensing and compressor units.

Pertinent Code Section(s)-27-770, 27-777.

Prescribed Tests - UL 1995.

Laboratory - Underwriters Laboratories Inc.

Test Reports - File SA7930, dated November 8, 1994, and September 16, 2002.

Description - Air-cooled compressor units, Model UAPB designed for installation. R-22 is the refrigerant used for the system. Unit consists of hermetic type compressor and controls. Units, with model numbers and cooling capacities, are listed below.

| Model No.   | Mfr.'s Specified Nominal Cooling Capacity (Tons) |
|-------------|--|
| UAPB-024JAZ | 2.0  |
| UAPB-030JAZ | 2.5  |
| UAPB-036JAZ | 3.0  |

Recommendation - That the above described air cooled condensing units be accepted for outdoor installation, when utilizing refrigerant R-22, under the following conditions:

1. All equipment shall be furnished with permanently affixed metal tags stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770 as to maximum sound levels permitted for exterior mechanical equipment.
2. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation.
3. All shipments and deliveries of such equipment shall be accompanied by a metal tag, certifying that the equipment shipped or delivered are equivalent to that tested and acceptable for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance 4/25/03

Examined by Shyam. Prasad