

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Material and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A., Commissioner
MEA 346-03-E

Report Materials and Equipment Acceptance Division

Manufacturer - Lennox Industries, Inc., 200 S. 12th Avenue, Marshalltown, IA 50158.

Trade Name - Elite, Dave Lenox Signature Collection.

Product - Coil blower units.

Pertinent Code Section(s) - 27-770, 27-777.

Prescribed Tests - RS 14-6 (ANSI Z21.47.1993), RS 13-11 (UL1995).

Laboratory - Underwriters Laboratories Inc.

Test Report - File SA11694 dated November 15, 1995, revised March 14, 2003.

Description - Coil blower units, designed for indoor installation. R-410A is the refrigerant used for the system. Unit consists of fin and tube type evaporator, evaporator blower and controls. Units, with model numbers and cooling capacities are listed below:

Model Number	Mfr.'s Specified Nominal Cooling Capacity (Tons)
CBX32M/CBX32V-030	2.5
CBX32M/CBX32V-036	3.0
CBX32M/CBX32V-042	3.5
CBX32M/CBX32V-048	4.0
CBX32M/CBX32V-060	5.0

Recommendation - That the above described coil blower unit, be accepted for use with Refrigerant R-410A, under the following conditions:

1. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided for in Section 27-131 of the Building Code.
2. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation.

Final Acceptance

11/28/03

Examined by

Stephen M. Hussey