

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A., Commissioner
MEA 368-03-E

Report of Material and Equipment Acceptance Division

Manufacturer – Nailor Industries, 4714 Winfield Road, Houston, TX 77039.

Trade Name(s) – Nailor Industries, Inc.

Product – Electric duct heaters.

Pertinent Code Section(s) - 27-792, 27-812.

Prescribed Test(s) – RS 14-6 (UL1096).

Laboratory – ETL Testing Laboratories, Inc.

Test Report(s) – No. 554250 dated January 20, 1995.

Description – Duct heaters are open coil heaters to be installed in buildings or homes in the duct work or installed in conjunction with air moving equipment to provide space heating. Heater models D(HA, HR, RR, RA, RP). The units are controlled by thermostat, duct stat or they may even be tied into and controlled by BMS.

Approved Models: D(HA, HR, RR, RA, RP)

Ratings: .1 kW through 1000 kW; fb 120, 208, 240, 277, 480, 550, or 600; fb/1, or fb/3.

Note: Minimum installed clearances from combustible construction shall be in accordance with RS 14-15 of the Building Code.

Recommendation – That the above electrical duct heaters, installed as per clearances to combustible construction specified above be accepted under the following conditions:

1. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.
2. Approval of electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation.

Final Acceptance

1/26/04

Examined By

Shyam. Bhusan