

## Report of Materials and Equipment Acceptance Division

NYC Department of Buildings 280 Broadway, New York, NY 10007 Patricia Lancaster, FAIA, Commissioner (212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 372-05-E

Manufacturer: Refrigeration Kool-Air, 19 Bauvais, Delson, Quebec,

J5B 1W5 CANADA

Trade Name(s): Kool-Air

**Product:** Air-cooled condensing units

Pertinent Code Section(s): 27-770, 27-777

Prescribed Test(s): RS 13-11B (ANSI B9.1), RS 13-11A (UL 1995)


Laboratory: CSA International

**Test Report(s):** No. 1529633, dated April 28, 2004.

**Description:** Condensing units and compressor units, permanently connected, for commercial use. Series "O" are outdoor units, series "I" are indoor units, series "R" are remote units and series "W" are water-cooled units. Remote and water-cooled units are for indoor installation. The condensing units and compressor units in this report are intended for installation in refrigeration systems employing refrigerants R-22, R-407C, R-134a, R-404A and R-507 where the working pressure does not exceed 400 psig.

## Model Nomenclature

The model designation is as follows:



Terms and Conditions: The above-described heating and cooling units are accepted under the following conditions:

- 1. Units shall use only Refrigerant R-410A.
- Units shall be installed indoors only.
- 3. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
- 4. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
- 5. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance //6/07/
Examined By Eyann