



# Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

## MEA 387-06-E

**Manufacturer:** Lennox Industries Inc., 200 S. 12<sup>th</sup> Avenue, Marshalltown, IA 50158

**Trade Name(s):** Lennox

**Product:** Split-system air conditioning units

**Pertinent Code Section(s):** 27-770, 27-777

**Prescribed Test(s):** RS 13-11B (ANSI B9.1), RS 13-11A (UL 1995, UL 465)

**Laboratory:** Underwriters Laboratories, Inc.

**Test Report(s):** File SA11694, dated June 16, 2005, revised March 3, 2006

**Description:** Split-system air conditioning units consisting of condensing units matched with indoor evaporator units. R-410A refrigerant is used for system. Unit is comprised of compressor, air-cooled condenser with fan, expansion valve, evaporator coil, and safety controls. Units, with model numbers and nominal cooling capacities, are listed below:

Model No.	Mfr's. Specified Nominal Cooling Capacity (Tons)
AC13-018	1.5
AC13-024	2.0
AC13-030	2.5
AC13-036	3.0
AC13-042	3.5
AC13-048	4.0
AC13-060	5.0

**Terms and Conditions:** The above-described split-system air conditioning units are accepted under the following conditions:

1. Units shall use only Refrigerant R-410A.
2. All equipment shall be furnished with a permanently affixed metal tag stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770, subdivision 4, as to maximum sound levels permitted for exterior mechanical equipment.
3. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.
4. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
5. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.

Final Acceptance 2/14/07

Examined By [Signature]