



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 411-07-E

Manufacturer: Wittus – Fire by Design
Eurimex
Postfach 1406
D-33378 Rheda-Wiedenbruck
GERMANY

Trade Name(s): Wittus – Fire By Design

Product: Residential room heater
MEA Index #300-10 – Fire Place

Pertinent Code Section(s): Subchapters 14, Article 19

Prescribed Test(s): UL 1482-96 – Solid fuel-type room heaters

Laboratory: OMNI-Test Laboratories, Inc.

Test Report(s): 339-S-01-2, dated October 2007.

Description: Model “Shaker” free-standing unit. Burns wood to give supplemental heating for space.

Terms and Conditions: The above-described factory-built fireplace is accepted for use as supplemental heating and decorative purposes under the following conditions:

1. Installation shall be in accordance with manufacturer’s supplied instructions and Section 27-848 of the New York City Building Code. Furthermore, the unit shall be vented in accordance with Section 27-845 of the Building Code.

2. Minimum clearance requirements of Reference Standard RS 14-15 shall be satisfied.
3. Approval of electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
4. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
5. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance April 29, 2008
Examined By Donald [Signature]