



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 420-07-E

Manufacturer: York International - Unitary Products Group
P.O. Box 19014
Wichita, KS 67204

Trade Name(s): York, Luxaire, Coleman, Fraser-Johnson, Guardian, Evcon

Product: Outdoor, air-cooled condensing units
MEA Index #20 -20 – Air Conditioning Equipment

Pertinent Code Section(s): 27-770, 27-777

Prescribed Test(s): RS 13-11B (ANSI B9.1), RS 13-8 (UL 303, UL 1995)

Laboratory: Underwriters Laboratories Inc.

Test Report(s): UL File SA3483, Volume 3 dated September 28, 2007.

Description: Air-cooled condensing units, designed for outdoor installation. R-22 is the refrigerant used for the system. Unit consists of sealed compressor, air-cooled condenser with fan and safety controls. Units, with model numbers and nominal cooling capacities, are listed below:

Model Number	Mfr's Specified Nominal Cooling Capacity, Tons
(T,G)CGD12	1
(T,G)CGD18	1.5
(T,G)CGD24	2
(T,G)CGD30	2.5
(T,G)CGD36	3
(T,G)CGD42	3.5
(T,G)CGD48	4
(T,G)CGD60	5

Note: Model number may have additional suffixes.

Terms and Conditions: The above-described air-cooled condensing units are accepted under the following conditions:

1. Units are for outdoor installation.
2. Units shall use only Refrigerant R-22.
3. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the Building Code.
4. A tag must be permanently affixed to the equipment stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770, as to maximum sound levels permitted for exterior mechanical equipment.
5. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
6. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.

Note: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance May 1, 2008

Examined By Simon Derkhdan