



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 430-07-E

Manufacturer: Jøtul North America, Inc.
55 Hutcherson Drive
Gorham, ME 04038

Trade Name(s): Jøtul

Product: Gas-fired, vented decorative fireplace appliances
MEA Index #410-70 – Heaters

Pertinent Code Section(s): 27-800, RS 14-2 (ANSI Z223)

Prescribed Test(s): RS 14-6 (ANSI Z21.88)

Laboratory: Intertek Testing Services NA, Inc.

Test Report(s): No. 3114144 dated August 23, 2007 & August 24, 2007.
No. 3073325 dated August 7, 2007, and
No. 3066521-01 dated August 7, 2007

Description: The **Jøtul GF 400 BV** is a freestanding, naturally-vented, gas-fired residential space heater consisting of a sheet steel firebox and cast-iron exterior. Overall dimensions are 24 inches deep x 28.5 inches high x 26.5 inches wide. It utilizes a piezo standing pilot ignition system and cast-iron/stainless steel burner with an input rating of 40,000 Btu/hr. An optional 115 VAC, 125 CFM blower is available.

The **Jøtul GF 600 DVII** is a freestanding, naturally-vented, gas-fired residential space heater, consisting of a sheet steel firebox and cast-iron exterior. Overall dimensions are 24 inches deep x 31 inches high x 29 inches wide. It utilizes a piezo standing pilot ignition system and cast-iron/stainless steel burner with an input rating of 40,000 Btu/hr. An optional 115 VAC, 125 CFM blower is available.

The models **GI 350 DV** and **GI 550 DV** are direct-vent gas fireplace inserts constructed of steel. Both models utilize a piezo standing pilot ignition system and 120 VAC, 125 CFM transflow blowers. Cast iron and steel facades are available in multiple styles and sizes for both models.

GI 350 DV Specifications: 15 inches deep x 18.5 inches high x 29 inches wide.
Maximum input rating is 28,000 Btu/hr.

GI 550 DV Specifications: 16 inches deep x 22.625 inches high x 34 inches wide.
Maximum input rating is 38,000 Btu/hr.

Terms and Conditions: The above-described appliances are accepted for decorative heating operation under the following conditions:

1. Installation shall be in accordance with listing laboratories' specifications, manufacturer's supplied instructions and Section 27-848 of the New York City Building Code.
2. Venting of the above equipment shall be accordance with Section 27-879 of the Building Code.
3. Liquid propane shall not be permitted.
4. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
5. Units shall be used in compliance with the Energy Conservation Construction of New York State.
6. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Note: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance May 9, 2008
Examined By Donald [Signature]