



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 436-04-E Vol. 3

Manufacturer: Electrolux Professional S.p.A. Via I Maggio, 2 Villotta Di Chinos (PN), ITALY 33089

Trade Name(s): Electrolux Professional S.p.A.

Product: Commercial refrigerators and freezers.

Pertinent Code Section(s): 27-777, 27-772.

Prescribed Test(s): RS 14-6 (UL 471)

Laboratory: Intertek Testing Services NA Inc.

Test Report(s): #10422035, dated August 3, 2004 and revised January 9, 2006.

Description: Commercial refrigerators and freezers for use in food service establishments. Units are comprised of on/off switches, refrigerator controllers, condensing units, outlet boxes, junction boxes, refrigerant dryers, evaporators, and evaporator fans. Condensing units are equipped with compressors, starting capacitors, condensers, condenser fans, interior lighting, fan motors and receivers. Evaporators are thermostatically controlled. R-22 is the refrigerant used for the system.

Product Covered:

| | | |
|----------------|--------------------|--------------------|
| Models: | 9VTX 726356 | 9VTX 726598 |
| | 9VTX 726371 | 9VTX 726599 |
| | 9VTX 726364 | 9VTX 726677 |
| | 9VTX 726372 | 9VTX 726678 |
| | 9VTX 726484 | 9VTX 726679 |
| | 9VTX 726485 | 9VTX 726680 |
| | 9VTX 726594 | S48P9P |
| | 9VTX 726597 | S48P9Q |

Electrical Ratings:

| Product No. | Voltage | Current | Frequency | Low Side Pressure | High Side Pressure |
|--|---------|---------|-----------|-------------------------------------|--------------------------------------|
| 9VTX 726356, 9VTX 726594 & 9VTX 726677 | 120 V | 6A | 60 Hz | 97 psig | 362 psig |
| 9VTX 726371, 9VTX 726598 & 9VTX 726679 | 120 V | 10A | 60Hz | 141 psig | 352 psig |
| 9VTX 726364, 9VTX 726597, 9VTX 726678 & S48P9P | 120 V | 12A | 60Hz | 174 psig | 334 psig |
| 9VTX 726372, 9VTX 726599, 9VTX 726680 & S48P9Q | 120V | 15A | 60Hz | 191 psig | 306 psig |
| 9VTX 726484 | 120V | 12A | 60Hz | 97 psig | 362 psig |
| 9VTX 726485 | 120V | 16A | 60Hz | Refr: 97 psig; Freezer: 174 psig | Refr: 362 psig; Freezer: 334 psig |

Terms and Conditions: The above commercial refrigerators and freezers are accepted under the following conditions:

1. Units shall be installed in accordance with manufacturer's instructions and New York City Building and Electrical Code requirements.
2. Adequate supply of fresh air for ventilation shall be provided into room or space enclosing equipment.
3. The installation shall not obstruct access for operation and servicing.
4. No flammable material (except electrical insulation) shall be located in the machine or wiring compartments unless specified.
5. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
6. Units shall be use in compliance with the Energy Conservation Construction Code of New York State.
7. All shipments and deliveries of such equipment shall be provided with a permanent tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the New York Building Code.

Final Acceptance 11/5/07

Examined By S. J. [Signature]