

Report of Materials and Equipment Acceptance Division

NYC Department of Buildings 280 Broadway, New York, NY 10007 Patricia Lancaster, FAIA, Commissioner (212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 459-06-E

Manufacturer: Lennox Industries, Inc.,

200 S. 12th Ave.

Marshaltown, IA 50158

Trade Name(s): Dave Lennox Signature Collection

Product: Packaged air conditioner units

Pertinent Code Section(s): 27-770, 27-777

Prescribed Test(s): RS 13-11A (UL 1995, UL 465)

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): File SA11694, dated March 7, 2006, revised July 14,

2006.

Description: Condensing units as described below:

Model Designation (1)	Capacity Rating – Tons
*XC15-024-230	2
*XC15-030-230	21/2
*XC15-036-230	3
*XC15-042-230	31/2
*XC15-048-230	4
*XC15-060-230	5

Note: * with additional suffixes

Terms and Conditions: The above described condensing units are accepted under the following conditions:

- 1. Units shall use only refrigerant R-416A.
- 2. All equipment shall be furnished with a permanently affixed metal tag stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770, subdivision 4, as to maximum sound levels permitted for exterior mechanical equipment.
- 3. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the Building Code.
- 4. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
- 5. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.

Final Acceptance 12/4/oc

Examined by Syam D