



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 470-06-E

Manufacturer: Rheem Manufacturing Co., P.O. Box 17010, Fort Smith, AR 72917-7010

Trade Name(s): Rheem, Ruud, Weatherking

Product: Outdoor air-cooled condensing and compressor units.

Pertinent Code Section(s): 27-770, 27-777

Prescribed Test(s): RS 13-6 (ANSI B9.1), RS 13-11 (CSA C22.2, No. 236; UL 1995).

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): No. SA7930, dated January 30, 2004.

Description: Commercial condensing units, Model RAWE-, designed for outdoor installation. R-22 is the refrigerant used for the system. Unit consists of air-cooled condenser, hermitically-sealed compressor, condenser fan motor and safety controls. Units are provided with an internal-relief assembly within the compressor.

Product Covered:

Model No.	Mfr.'s Specified Nominal Cooling Capacity, Tons
RAWE-079*	6.5
RAWE-091*	7.5

* Denotes additional characters in model number

Terms and Conditions: The above outdoor air-cooled condensers are accepted under the following conditions:

1. Units shall only use Refrigerant R-22.
2. If utilized for residence heating, the circulatory air system shall have (a) one register or grille without closeable shutters and the duct leading thereto shall be without a damper, or (b) dampers and shutters within the system shall be constructed or controlled so as to prevent closure beyond 80 percent of the gross duct area at all times.
3. All equipment shall be furnished with a permanently affixed metal tag stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770 as to maximum sound levels permitted for exterior mechanical equipment.
4. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the New York City Building Code.
5. Approval of electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
6. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.

Final Acceptance 11/28/06

Examined By Stephen P. [Signature]