



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 498-06-E

Manufacturer: Brass

Craft Mfg. Co.
39600 Orchard Hill Place
Novi, MI 48375

Trade Name(s): Brass Craft

Product: Excess flow gas valves

Pertinent Code Section(s): 27-826, RS 14-2 (ANSI Z223.1)

Prescribed Test(s): CSA US3-92

Laboratory: CSA International

Test Report(s): 1361723 dated December 17, 2003.

Description: Excess flow gas valves, product #3371-87, in various sizes for use with natural gas.

Model No.	Size
EU2-6L	3/8 M x 3/8 fl.
EU2-6-8L	Combination: 1/2 M x 3/8 F x 3/8 fl.
EU2-6-12L	Combination: 3/4 M x 1/2 F x 3/8 fl.
EU4-6-8L	Combination: 1/2 M x 3/8 F x 3/8 fl.
EU4-6-12L	Combination: 3/4 M x 1/2 F x 3/8 fl.
EU2-8-6L	3/8 M x 1/2 fl.
EU2-8L	Combination: 1/2 M x 3/8 F x 1/2 fl.
EU2-8-12L	Combination: 3/4 M x 1/2 F x 1/2 fl.
EU1-8-12L	3/4 M x 1/2 fl.

Terms and Conditions: The above-described excess gas flow valves are accepted under the following conditions:

1. Valves shall be used with natural gas fire appliances.
2. Valves shall meet the requirements of RS 14-2, and p115.7 of RS 16 of the New York City Building Code.
3. Valves shall be installed so as to be protected against physical and thermal damage.
4. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
5. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
6. All shipments and deliveries of such valves shall be provided with a metal tag, suitably placed, certifying that the valves shipped or delivered are equivalent to those tested and accepted for use, as provided in Section 27-131 of the Building Code.

Financial Acceptance 1/23/08
Examined By Stegens, G.W.