



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 50-07-E

Manufacturer: Marlo Mfg. Co., Inc., 301 Division Street, Boonton, N.J. 07005

Trade Name(s): Marlo

Product: Self-contained commercial refrigerated show cases

Pertinent Code Section(s): 27-771, 27-772, 27-777(f)

Prescribed Test(s): RS 14-6 (UL 471)

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): UL File SA7037, dated June 26, 1996

Description: Self-contained, commercial refrigerated showcases, as tabulated below. These are display units with or without glass enclosures. Units do not employ a defrost system. Units are comprised of on/off switches, refrigeration controllers, condensing units, junction boxes, and evaporators. Condensing units are equipped with compressors, starting capacitors, condensers, interior lighting and receivers.

Model No.	Voltage	Refrigerant
LBSC-7224	115V	401A (56 oz.)
LBSC-7230	115V	401A (56 oz.)

Terms and Conditions: The above-described self-contained refrigerated showcases are accepted under the following conditions:

1. Units shall be installed in accordance with manufacturer's instructions and New York City Electrical Code requirements.
2. Adequate supply of fresh air shall be provided for ventilation into room or space enclosing equipment.
3. The installation shall not obstruct access for operation and servicing.
4. No flammable material (except electrical insulation) shall be located in the machine or wiring compartments unless specified.
5. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
6. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
7. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance 7/19/07
Examined By 