



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Robert D. LiMandri, Acting Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 51-08-E

Manufacturer: TRANE
4811 South Zero Street
Fort Smith AR 72903

Trade Name(s): TRANE or AMERICAN STANDARD

Product: Self-contained dual fuel heat pumps – gas / electric
MEA Index #20 – Air Conditioning Equipment

Pertinent Code Section(s): 27-770, 27-777, 27-800, RS 14-2 (ANSI Z223.1)

Prescribed Test(s): RS 13-11B (ANSI B9.1), RS 13-13 (UL 1995, UL 559),
RS 14-6 (ANSI Z21,47)

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): UL File SA11679 dated August 4, 2007.

Description: Series **4DCZ6** are 3-ton thru 5-ton single packaged, self-contained dual fuel heat pumps designed for outdoor installation, rooftop or ground level. Units have hermetically sealed compressors, are air-cooled, employ evaporator, expansion valves and controls. They employ refrigerant R410A. An electrically operated reversing valve is provided to initiate the reverse heat cycle. They are a combination of our 4WCZ6 heat pumps with the addition of the 4YCZ6 gas furnace section. Units, with model numbers, heating and cooling capacities, are listed below:

Model No.	Nominal Cooling Capacity (Btu/hr)	Number of Burners and Burner Tubes	Nominal Heating Input, (Btu/hr) Low Fire	Nominal Heating Input, (Btu/hr) High Fire
4DCZ6036A1075*	36,000	2	56,250	75,000
4DCZ6036A3075*	36,000	2	56,250	75,000
4DCZ6048A1096*	47,500	3	72,000	96,000
4DCZ6048A3096*	47,500	3	72,000	96,000
4DCZ6060A1120*	57,000	3	90,000	120,000
4DCZ6060A3120*	57,000	3	90,000	120,000

Terms and Conditions: The above-described rooftop heating/cooling units are accepted under the following conditions:

- 1) Units shall be installed outdoors only.
- 2) Heating section must operate on natural gas and cooling section employs only Refrigerant R-410A.
- 3) If utilized for residence heating, the circulatory air system shall have (a) one register or grille without closable shutters and the duct leading thereto shall be without a damper, or (b) dampers and shutter within the system that shall be constructed or controlled so as to prevent closure beyond 80 percent of the gross duct area at all times.
- 4) All equipment shall be furnished with a permanently affixed metal tag stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770, Subdivision 4 of the New York City Building Code, as to maximum sound levels permitted for exterior mechanical equipment.
- 5) Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
- 6) Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
- 7) All equipment and deliveries of such equipment shall be suitably labeled certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

NOTE: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance May 20, 2008

Examined By Sean Derkhdorn