

## Report of Materials and Equipment Acceptance Division

NYC Department of Buildings 280 Broadway, New York, NY 10007 Patricia Lancaster, FAIA, Commissioner (212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

## MEA 539-06-E

Manufacturer: Liebert Corporation, 1050 Dearborn Drive,

Columbus, OH 43229

Trade Name(s): Liebert

**Product:** Fan coil heat-rejection, fluid cooler units

Pertinent Code Section(s): 27-770, 27-777

Prescribed Test(s): RS 13-11B (ANSI B9.1), RS 13-11A (UL 1995)

Laboratory: CSA International

**Test Report(s):** No. 1075063, dated October 16, 2006

**Description:** Permanently connected, special purpose fan coil heat rejection units designed for free-standing outdoor use with vertical air discharge. Units are field-charged with refrigerants R22 and R407C, and are rated for 208, 230, 460, or 575 volt, 3 phase, 60Hz electric power. The heat rejection units may be equipped with optional electric receiver heaters.

	Manufacturer's Specified Nominal Heat Rejection Capacity (Btu/hr) (@ 30°F TD)	
Model #	R-22	R-407C
CD*/*CM*/*CS* 063	71430	64350
CD*/*CM*/*CS* 083	88020	70740
CD*/*CM*/*CS* 104	124890	106500
CD*/*CM*/*CS* 119	105570	82110
CD*/*CM*/*CS* 127	136710	11150
CD*/*CM*/*CS* 143	160560	140070

# = Model number may also have variable prefix and/or suffix digits.

	Manufacturer's Specified Nominal Heat Rejection Capacity BTUH (@ 30°F TD)	
Model #	R-22	R-407C
CD*/*CM*/*CS* 165	178410	143160
CD*/*CM*/*CS* 205	264930	242100
CD*/*CM*/*CS* 214	222600	182760
CD*/*CM*/*CS* 251	298170	277380
CD*/*CM*/*CS* 286	292500	239250
CD*/*CM*/*CS* 308	384180	337890
CD*/*CM*/*CS* 409	439350	356730
CD*/*CM*/*CS* 415	507690	473850
CD*/*CM*/*CS* 510	552240	452820
CD*/*CM*/*CS* 572	58500	478500
CD*/*CM*/*CS* 616	768360	675780
CD*/*CM*/*CS* 830	1015380	944640
CD*/*CM*/*CS* 1010	1104480	905640

<sup># =</sup> Model number may also have variable prefix and/or suffix digits.

Terms and Conditions: The above-described fan coil heat rejection units are accepted under the following conditions:

- 1. Units may use only Refrigerants R-22 or R407C.
- 2. Units shall be installed outdoors.
- 3. A tag must be permanently affixed to the equipment stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770, as to maximum sound levels permitted for exterior mechanical equipment.
- 4. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
- 5. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
- 6. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the New York City Building Code.

Final Acceptance 19/19/07

Examined By Super-O