



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 541-06-E

Manufacturer: Alto-Shaam, Inc., W164 N9221 Water Street, Menomonee Falls, WI 53052

Trade Name(s): Alto-Shaam

Product: Gas-fired convection oven

Pertinent Code Section(s): 27-800, 27-826, RS 14-2 (ANSI Z223.1)

Prescribed Test(s): RS 14-6 (ANSI Z83.11)

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): UL File MH19597, dated January 6, 2006, revised January 18, 2006

Description: Gas-fired commercial convection oven, as listed below. Unit is comprised of main burner, thermostat, and combination control for power burner, high temperature limit device, gas pressure regulator and intermittent ignition.

Model No.	Description
ASC-4G (may have suffixes and/or prefixes) ASC-6G (may have suffixes and/or prefixes)	Gas-fired convection ovens

Note:

Minimum installed clearances from combustible construction shall be in accordance with RS 14-15 of the New York City Building Code.

Terms and Conditions: The above gas-fired commercial convection ovens are accepted under the following conditions:

1. Units shall be fired with natural gas only.
2. Units shall be installed in accordance with manufacturer's instructions and New York City Electrical, Building and Fire Codes requirements.
3. Cooking equipment shall be installed under hoods that vent to the outside and comply with Reference Standard RS-13 requirements of the New York City Building Code and have a fire-suppression system complying with Reference Standards RS 13-2 and RS 13-3 with open heads and capable of simultaneous discharge and manual release. The fire-suppression system exclusively used for cooking equipment shall be filled with the Building Department and examined and approved by the Fire Department.
4. Adequate supply of fresh air shall be provided into room or space enclosing equipment for unit ventilation and combustion requirements.
5. The installation shall not obstruct required access for operation and servicing.
6. For grease removal, suitable baffle-type grease filters, MEA-accepted, shall be installed.
7. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
8. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
9. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance 423/06

Examined By [Signature]

