

**CITY OF NEW YORK  
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Material and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, F.A.I.A., Commissioner

**MEA 58-05-E  
Report of Material and Equipment Acceptance Division**

**Manufacturer- International Comfort Products Corporation, 650 Heil Quaker Avenue, Lewisburg Tennessee 37091.**

**Trade Name-Heil, Comfortmaker, Airstream, ICP Commercial.**

**Product- Packaged air conditioning units.**

**Pertinent Code Section(s)- 27-770, 27-777.**

**Prescribed Test(s)- RS 13-6 (ANSI B9.1), RS 13-11 (UL 465), UL 1995.**

**Laboratory- Underwriters Laboratories Inc.**

**Test Report- UL File SA 1153 dated May 23, 2003.**

**Description- Packaged self contained, air cooled, air conditioning units, designed for outdoor installation in residential buildings. R-22 is the refrigerant used for the system. Unit consists of hermetically sealed compressor, air cooled condenser with fan, evaporator coil with blower, and safety controls. Automatic pressure limiting device is set at 420 psi. Units, with model numbers and nominal cooling capacities are listed below:**

<b>Model No.</b>	<b>Mfr.'s Specified Nominal Cooling Capacity BTUH</b>
<b>PA (B,MD)036</b>	<b>36,000</b>
<b>PA (B,MD)048</b>	<b>48,000</b>
<b>PA (B,MD)060</b>	<b>60,000</b>
<b>PA (B,MD)075</b>	<b>75,000</b>

**Recommendation - That the above described air cooled, air conditioning units, be accepted for outdoor installation, when utilizing refrigerant R-22, under the following conditions.**

- 1. All equipment shall be furnished with permanently affixed metal tags stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770 subdivision 4, as to maximum sound levels permitted for exterior mechanical equipment.**
- 2. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.**
- 3. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation.**

Final Acceptance April/25/2005  
Examined By S. Derkshuter