



## Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

### **MEA 604-06-E**

**Manufacturer:** Perlick Corporation, 8300 W. Good Hope Road, Milwaukee, WI 53223

**Trade Name(s):** Perlick

**Product:** Commercial refrigerators and freezers, remote systems

**Pertinent Code Section(s):** 27-771, 27-772, 27-777(f)

**Prescribed Test(s):** RS 14-6 (UL 471)

**Laboratory:** Underwriters Laboratories, Inc.

**Test Report(s):** UL File SA2110, dated May 20, 1996 and revised February 12, 2006

**Description:** Commercial refrigerators and freezers (remote systems) are used for cooling bulk beverages. Units are intended for indoor use and for free-standing installation. Remote models are field-connected and employ remote-condensing unit. Units are comprised of on/off switches, remote condenser, interconnecting refrigerant lines and evaporators. Evaporator is combined with fan motors, drain opening and mechanical type expansion valve. Types of refrigerants used for these units are R-134A, R12, R22 and MP39. Supply voltage is 115(V). Unit with model numbers are listed below:

**Back Bars: BR48, BR72, BR96, PR48, PR72**

#### Notes:

1. These units have different length and storage capacities; other parts are identical.
2. Units may have stainless steel flat top or enclosure.

**Terms and Conditions:** The above commercial refrigerators and freezers, remote systems, are accepted under the following conditions:

1. Units shall be installed in accordance with manufacturer's instructions and New York City Electrical Code requirements.
2. Adequate supply of fresh air for ventilation shall be provided into room or space enclosing equipment.
3. The installation shall not interfere with accessibility for operation and servicing.
4. No flammable material (except electrical insulation) shall be located in the machine or wiring compartments unless specified.
5. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
6. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
7. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the Building Code.

Final Acceptance 1/8/07

Examined By Shuja M. Qureshi