

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

**Patricia J. Lancaster, F.A.I.A., Commissioner
MEA 75-04-E**

Report of Material and Equipment Acceptance Division

Manufacturer – Kool-Air Inc., 100 Conrad Gosselin Street, Iberville, Quebec, Canada J2X 5L5.

Trade Name(s) – Kool-Air.

Product – Refrigeration Unit cooler.

Pertinent Code Section(s) – 27-770, 27-777.

Prescribed Test(s) – RS 13-11 (UL 1995).

Laboratory – CSA International, Inc.

Test Report(s) – No. 1416406, dated March 14, 2003.

Description – Air cooled condensers, fluid coolers and heat reclaim units, stationary, for indoor or outdoor installation, commercial use, consisting of finned coils and motor driven fan, models: Series C (condenser), Series H (heat recovery), Series F (fluid). Identification Series C, H, F are followed by letters and numbers (D or E/ V or H/ A, B, C, or D/ 1 or 2/ 1, 2, 3, 4, 5, or 6/ 2, 3, 4, 5, or 6/ 08, 09, 10, 11, 12/ 2, 5, 8, 9). R-22 and R-404A are the refrigerants used for the system. Manufacturer specified cooling capacities vary in the range of 5 tons to 200 tons.

Recommendation - That the above described units, be accepted, under the following conditions:

- 1. All equipment shall be furnished with a permanently affixed metal tag, stating tat if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770, subdivision 4, as to maximum sound levels permitted for exterior mechanical equipment.**
- 2. All shipments and deliveries of such equipment shall be provided with a laboratory label and a permanent tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.**
- 3. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation.**

Final Acceptance 9/27/04

Examined By Shyam