



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 86-06-E

Manufacturer: Bryant Heating & Cooling Systems, 7310 West Morris Street, Indianapolis, Indiana 46231

Trade Name(s): Bryant

Product: Single package rooftop heat pump

Pertinent Code Section(s): 27-770, 27-777

Prescribed Test(s): RS 13-11B (ANSI B9.1), RS 13-13 (UL559, UL1995)

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): UL File SA11583, Volume 7, Section 10, dated October 31, 2004

Description: Single packaged heat pump unit designed for rooftop or outdoor installation. Unit employs refrigerant R-410A. Unit is comprised of compressor, air cooled condenser, evaporator coil with blower, expansion valve, pressure-limiting devices, accumulator, reversing valve and safety control. Units with capacities are listed below:

Model Number	Nominal Cooling Capacity, Tons	Heating Pump Heating Range Capacity (BTUH)
604B*-024*****	2	14,400-24,000
604B*-030*****	2.5	16,000-29,000
604B*-036*****	3	19,600-36,000
604B*-042*****	3.5	21,600-40,500
604B*-048*****	4	24,600-47,000
604B*-060*****	5	31,000-55,000

* indicates voltage: N= 208/230-1, P=208/230-3, E=460-3

- indicates variations, may be any letter

***** indicates options or digit not used

Terms and Conditions: The above-described heat pump units are accepted under the following conditions:

1. Units shall be installed outdoors.
2. Units shall use only Refrigerant R-410A.
3. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.
4. A tag must be permanently affixed to the equipment stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770 as to maximum sound levels permitted for exterior mechanical equipment.
5. If utilized for residence heating, air circulation system shall have (a) one register or grille without closable shutters and the duct leading thereto shall be without a damper, or (b) dampers and shutters within the system that shall be constructed or controlled so as to prevent closure beyond 80 percent of the gross duct area at all times.
6. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
7. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.

Note: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance October 31, 2006

Examined By Simon Darkhol