



# Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Robert D. LiMandri, Acting Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

## MEA 97-08-E

**Manufacturer:** International Comfort Products, LLC  
7310 W. Morris Street  
Indianapolis, IN 46231

**Trade Name(s):** Arcoaire, Airquest, Comfortmaker, Day & Night, Heil, ICP Commercial, KeepRite, Maratherm, Tempstar

**Product:** High-wall, duct-free split system indoor units  
MEA Index #20-120 – Air Conditioning System

**Pertinent Code Section(s):** 27-770, 27-777

**Prescribed Test(s):** RS 13-11B (ANSI B9.1), RS 13-7 (UL 207, UL 1995)

**Laboratory:** Intertek Testing Services

**Test Report(s):** Report No. 3130421CRT-002 dated December 18, 2007.

**Description:** High-wall, duct-free split system heat pump indoor units with Puron (R410A) refrigerant. Units are comprised of indoor coils, blowers and safety controls. Model numbers and nominal cooling capacities are listed below:

Model No.	Mfr's. Specified Nominal Cooling Capacity (Tons)
DFF4AH09	.75
DFF4AH12	1
DFF4AH18	1.5
DFF4AH24	2

**Terms and Conditions:** The above-described split system indoor units are accepted under the following conditions:

1. Units shall use only Refrigerant R-410A.
2. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
3. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
4. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Note: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance July 14, 2008

Examined By Sium Derphidan