



DEPARTMENT OF BUILDINGS

EXECUTIVE OFFICES  
120 WALL STREET, NEW YORK, N.Y. 10005

CHARLES M. SMITH, Jr., R.A., Commissioner  
248-8811

December 26, 1984

Mr. Gordon H. Smith  
Gordon H. Smith Corporation  
200 Madison Avenue  
New York, N.Y. 10016

Re: Rules and Regulations  
Relating to the Design and  
Installation of Curtain  
Wall and Panel Wall  
(Non-Load Bearing Exterior  
Wall) Systems.

Dear Mr. Smith:

This is in response to your letter to me, dated November 26, 1984, inquiring whether or not conventionally constructed field laid-up masonry walls fall within the scope of the above rules and regulations.

Please be advised that such panel walls are subject to controlled inspection pursuant to Section C26-106.3 of The Administrative (Building) Code and the subject rules.

Very truly yours,

*Irving Polsky, P.E.*

Irving Polsky, P.E.  
Executive Engineer

IP/lw

cc: I.E. Minkin, P.E., Deputy Commissioner  
Boro Supts.

2007